

TEST

ACID NUMBER, MG KOH/G
 AROMATICS, VOL%
 OLEFINS, VOL%
 SATURATES, VOL%
 DOCTOR TEST
 SULFUR CONTENT, WT%
 DISTILLATION, IBP, °C
 DISTILLATION, 5%, °C
 DISTILLATION, 10%, °C
 DISTILLATION, 20%, °C
 DISTILLATION, 30%, °C
 DISTILLATION, 40%, °C
 DISTILLATION, 50%, °C
 DISTILLATION, 60%, °C
 DISTILLATION, 70%, °C
 DISTILLATION, 80%, °C
 DISTILLATION, 90%, °C
 DISTILLATION, 95%, °C
 DISTILLATION, DP, °C
 RECOVERY, VOL%
 RESIDUE, VOL%
 LOSS, VOL%
 PMCC FLASHPOINT, °F
 DENSITY @ 15.00°C, KG/L
 FREEZE POINT, °C
 KIN. VISCOSITY@ -20°C, CST
 NET HEAT OF COMBUSTION, MJ/KG
 CETANE INDEX
 HYDROGEN CONTENT, WT%
 SMOKE POINT, MM
 NAPHTHALENES, VOL%
 COPPER CORROSION
 CHANGE IN PRESSURE DROP, MM OF HG
 TUBE DEPOSIT CODE
 EXISTENT GUM (WASHED) MG/100ML

SPECIFICATION

0.100, MAX.
 25, MAX.
 REPORT
 REPORT
 NEGATIVE
 0.3, MAX.
 REPORT
 REPORT
 205, MAX
 REPORT
 REPORT
 REPORT
 REPORT
 REPORT
 REPORT
 REPORT
 REPORT
 REPORT
 REPORT
 REPORT
 300, MAX.
 REPORT
 1.5, MAX.
 1.5, MAX.
 38, MIN.
 0.775 – 0.840
 -40, MAX.
 8.00, MAX.
 42.8, MIN.
 REPORT
 13.40, MIN.
 18.0, MIN.
 3.0, MAX.
 1, MAX.
 25, MAX.
 3, MAX.
 7.0, MAX.

METHOD

ASTM D3242
 ASTM D1319
 ASTM D1319
 ASTM D1319
 ASTM D4952
 ASTM D5453
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D86
 ASTM D93
 ASTM D4052
 ASTM D2386
 ASTM D445
 ASTM D3338
 ASTM D976
 ASTM D3701
 ASTM D1322
 ASTM D1840
 ASTM D130
 ASTM D3241
 ASTM D3241
 ASTM D381

Note: This information is offered for your consideration, investigation and verification. It should not be construed as a warranty or guaranty.

rethink_refine_resolve

Follow us on:



Office: 248_541_3824
 Fax: 248_541_8970

821 Wanda Avenue
 Ferndale, MI 48220

gageproducts.com



JET A FUEL 42365

MICRO SEPAROMETER RATING
CONDUCTIVITY, PS/M

70, MIN
50.00 – 450.00

ASTM D3948
ASTM D2624

Note: This information is offered for your consideration, investigation and verification. It should not be construed as a warranty or guaranty.

rethink_refine_resolve

Office: 248_541_3824
Fax: 248_541_8970

821 Wanda Avenue
Ferndale, MI 48220

Follow us on:



gageproducts.com