



JET A-1 FUEL 42366

MICRO SEPAROMETER RATING
CONDUCTIVITY, PS/M

70, MIN
50.00 – 450.00

ASTM D3948
ASTM D2624

Note: This information is offered for your consideration, investigation and verification. It should not be construed as a warranty or guaranty.

rethink_refine_resolve

Follow us on:



Office: 248_541_3824
Fax: 248_541_8970

821 Wanda Avenue
Ferndale, MI 48220

gageproducts.com