



# Gage Products Company Technical Data Sheet

Page: 1

Date Printed: 12/17/19 at 2:12 PM

Jet A Fuel  
42704-1BL

Test	Method	UOM	Specification
ACID NUMBER	ASTM D3242	MG KOH/G	0.100, MAX
AROMATIC CONTENT	ASTM D1319	VOL. %	25.0, MAX
OLEFIN CONTENT	ASTM D1319	VOL. %	REPORT
SATURATE CONTENT	ASTM D1319	VOL. %	REPORT
DOCTOR TEST	ASTM D4952		NEGATIVE
SULFUR CONTENT	ASTM D5453	WT. %	0.3000, MAX
DISTILLATION, IBP	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 5%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 10%	ASTM D86	DEG C (DEG F)	205.0 (401.0), MAX
DISTILLATION, 20%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 30%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 40%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 50%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 60%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 70%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 80%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 90%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, 95%	ASTM D86	DEG C (DEG F)	REPORT
DISTILLATION, DRY POINT	ASTM D86	DEG C (DEG F)	300.0 (572.0), MAX
RECOVERY	ASTM D86	VOL. %	REPORT
RESIDUE	ASTM D86	VOL. %	1.5, MAX
LOSS	ASTM D86	VOL. %	1.5, MAX
PMCC FLASH POINT	ASTM D93	DEG C	38.0 (100.4), MIN
DENSITY @ 15.00 C	ASTM D4052	KG/L	0.775 - 0.840
FREEZE POINT	ASTM D2386	C	-40, MAX
KIN. VISCOSITY @ -20C	ASTM D445	CST	8.00, MAX
NET HEAT OF COMBUSTION	ASTM D3338	MJ/KG	42.8, MIN.
CETANE INDEX	ASTM D976	CETANE INDEX	REPORT
HYDROGEN CONTENT	ASTM D3701	WT%	13.40, MIN
SMOKE POINT	ASTM D1322	MM	18.0, MIN
NAPHTHALENES	ASTM D1840	VOL%	3.0, MAX
COPPER CORROSION	ASTM D130	COPPER CORR.	1, MAX
CHANGE IN PRESSURE DROP	ASTM D3241	MM OF HG	25, MAX

**NOTE: This information is offered for your consideration, investigation, and verification. It should not be construed as a warranty or guaranty.**

rethink\_refine\_resolve®

Office: 248\_541\_3824  
Fax: 248\_541\_8970

821 Wanda Avenue  
Ferndale, MI 48220

gageproducts.com



# Gage Products Company Technical Data Sheet

Page: 2

Date Printed: 12/17/19 at 2:12 PM

Jet A Fuel  
42704-1BL

TUBE DEPOSIT CODE	ASTM D3241		3, MAX
EXISTENT GUM (WASHED)	ASTM D381	MG/100ML	7.0, MAX.
MICRO SEPAROMETER RATING	ASTM D3948	MIN	70, MIN.
CONDUCTIVITY	ASTM D2624	PS/M	50.00 - 450.00
STADIS SOLN ADDED	YES		Y/N

**NOTE:** This information is offered for your consideration, investigation, and verification. It should not be construed as a warranty or guaranty.

rethink\_refine\_resolve®

Office: 248\_541\_3824  
Fax: 248\_541\_8970

821 Wanda Avenue  
Ferndale, MI 48220

[gageproducts.com](http://gageproducts.com)